TAMILNADU FIRE AND RESCUE SERVICE DEPARTMENT

NO OBJECTION CERTIFICATE

R.C.No:153/V/2024 Fire & Rescue Services Station, Avadi.

NOC NO:14/2024 Date: 02.02.2024

Subject: Fire & Rescue Services Department– Avadi Fire & Rescue Services Station for purpose no objection certificate – Reg.

Ref: 1. G.O.No.122 / Dept. Of school Education (2) / Dated 14.09.2004

- 2. G.O.No.123 / Dept. Of School Education (2) / Dated 14.09.2004
- 3. Date of Requisition letter from Correspondent, VGN Chinmaya Vidayalaya 01.02.2024

Based on the Govt. Order mentioned above and the requisition letter given by the VGN Chinmaya Vidyalaya at Sekkadu Main Road, Avadi, Chennai – 600071, Tamil Nadu the building premises comprises of G + 3 owned / occupied by M/S: VGN CHINMAYA VIDYALAYA, have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 01.02.2024 in the presence of Sri.Rajkumar Devarajan, Correspondent and that the school is granted NOC for a period of one year from 02.02.2024 to 01.02.2025 subject to the conditions stated below.

THE ABOVE PREMISES INSPECTED BY STATION OFFICIER FIRE & RESCUE SERVICES, <u>G.MUTHUKRISHNAN</u> ON <u>01.02.2024</u>

CONDITIONS

- 1. This License is valid for ONE YEAR month from the date of issue.
- 2. Fire Safety Systems should be maintained in good working condition.
- 3. Mock drill to be conducted periodically with the help of local fire brigade.
- 4. Any erection of permanent or temporary structure should be intimated to this department.
- A trained Fire Service Person, preferably retired one should be appointed.
- 6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a) Building Occupancy capacity should not be more than 4 people per Sq.meter as per the National Building Code – 2005.
 - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.

- c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance the capacity of the classrooms shall have to be limited 45 students.
- d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
- e) Mock drill has to be conducted at regular intervals in consultation with the Divisional Officer, Fire and Rescue Services, Chennai Suburban District at Ambattur.
- f) The classrooms should always be in the ground floor upto 3rd Standards.
- g) The classrooms doors/windows should be made of either noncombustible material or materials with high fire-resistance rating.
- h) The classrooms doors/windows shall always open outwards.
- The classrooms doors/windows shutter when opened should not obstruct movement along the exit or escape route.
- j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the classroom with only a simple latch/lower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
- k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.

If there is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.

BOIS OZ. OZ. 2024 2 * PLADI, CHENNAL - 600 0000

STATION OFFICER

FIRE & RESCUE SERVICE STATION

AVADI, CHENNAI - 600 054.

To Sri.Rajkumar Devarajan, Correspondent, VGN CHINMAYA VIDYALAYA, Sekkadu Main Road, Avadi, Chennai – 600071.